



ORANI WATER DISTRICT

Orani, Bataan, Philippines

Tel. No. (+6347) 431-1364

www.oraniwater.com.ph

e-mail: helpdesk@oraniwater.com.ph

SUPPLEMENTAL/ BID BULLETIN NO. 1

RE: INVITATION TO BID FOR THE SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF SUPERVISORY CONTROL AND DATA ACQUISITION (SDADA) SYSTEM

November 16, 2017

REVISIONS ON BIDDING DOCUMENTS

This Supplemental Bid Bulletin is being issued to clarify, modify, or amend items in the Bidding Documents.

The following Items are hereby revised/amended:

SECTION VII. TECHNICAL SPECIFICATIONS/TOR

FROM	TO
Control system (HMI) with data storage capability per sub-station enclosed in aluminum housing with glass front and protection class of IP65 and running with Microsoft Embedded Compact 7. <i>(Page 72 second bullet)</i>	Control system (HMI with 8.4" screen) with data storage capability per sub-station enclosed in aluminum housing with glass front and protection class of IP65 and running with Microsoft Embedded Compact 7.
AND Supply additional five (5) electromagnetic flowmeters & pressure transmitters, EXCLUDING their installation, as indicated below: <i>(Page 73 last bullet)</i>	AND Supply and integration of five electromagnetic flowmeters & pressure transmitters, EXCLUDING their installation, as indicated below:

For further inquiries, you may coordinate with the OWD Bids and Awards Committee Secretariat at Tel. No. 047-300-3429.

Please be guided accordingly.

CONRADO D. BUENAVENTURA, JR

Chairman, OWD Bids and Awards Committee